GOVERNMENT OF TELANGANA
ABSTRACT

MA&UD Department – Engineering - Hyderabad Metropolitan Water Supply and Sewerage Board -"In-situ Rehabilitation of 1600/1800mm dia trunk sewer main (Duplicate A main) from Divyashakti Apartments to 20MLD STP at Hussain Sagar Lakeusing trenchless structural lining system" – Administrative sanction for an amount of Rs.91.00 Crs (Rupees Ninty One Crores)– Accorded - Orders - Issued.

METROPOLITAN AREA & URBAN DEVELOPMENT (ENGG.2) DEPARTMENT

G.O.Rt.No. 173 **Dated: 10-02-2026**
Read:-

From the MD, HMWSSB, Hyderabad, Lr.No.HMWSSB/MD/Trunk Sewers/Trenchless/2024-25/32, Dt:28.01.2025, Dt:07.05.2025 and Dt:11.10.2025.

****

ORDER:

The Managing Director, Hyderabad Metropolitan Water Supply and Sewerage Board, Hyderabad in the letters read above, cited, has stated that the sewer network within Hyderabad Metropolitan Water Supply and Sewerage Board jurisdiction comprises laterals, sub-mains, and trunk mains connected to Sewage Treatment Plants (STPs), with a total length of about 7,200 km, including approximately 390 km of sewers above 600 mm diameter. The trunk sewer mains and their manholes are deteriorating due to corrosion of concrete and steel reinforcement caused by corrosive gases and wastewater entering from open nalas through Interception and Diversion structures. As it is not feasible to lay parallel sewer mains by dismantling the existing ones, and to avoid significant inconvenience to traffic on busy roads, the rehabilitation of these trunk sewers must be carried out using trenchless technology. Accordingly, to revive the pipelines and enhance their service life by another 30–50 years, the trunk sewer mains need to be rehabilitated using Cured-In-Place Pipe (CIPP), Machine Wound Spiral Lining (MWSL), or other suitable trenchless technology methods.

2. The Managing Director, Hyderabad Metropolitan Water Supply and Sewerage Board, Hyderabad, has therefore requested the Government to accord Administrative sanction for an amount of Rs.91.00Crs (Rupees Ninty One Crores) for the work "In-situ Rehabilitation of 1600/1800mm dia trunk sewer main (Duplicate A main) from Divyashakti Apartments to 20MLD STP at Hussain SagarLakeusing trenchless structural lining system" duly charging the expenditure to the HoA 6215-01-190-00-08-001-000 implementation of the said project works.

3. Government, after careful examination of the matter, herebyaccord Administrative sanction for an amount of Rs.91.00 Crs (Rupees Ninty One Crores) for the work "In-situ Rehabilitation of 1600/1800mm dia trunk sewer main (Duplicate A main) from Divyashakti Apartments to 20MLD STP at Hussain Sagar Lake using trenchless structural lining system" duly charging the expenditure to the HoA “6215-01-190-00-08-001-000”and to take up the works by Hyderabad Metropolitan Water Supply and Sewerage Board, Hyderabad.

(P.T.O)

4. The Managing Director, Hyderabad Metropolitan Water Supply & Sewerage Board, Hyderabad shall take further action, accordingly.

5. This order issues with the concurrence of Finance (DCM) Department vide U.O.No.3391576/400/A2/DCM/2025, dt.20.11.2025.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF TELANGANA)

JAYESH RANJAN
SPECIAL CHIEF SECRETARY TO GOVERNMENT

To
The Managing Director, Hyderabad Metropolitan Water Supply and Sewerage Board, Hyderabad.

Copy to:
P.S to Secretary to Hon'ble Chief Minister.
PS to Spl.CS to Government, MA&UD Department.
The Finance (DCM) Department.
SF/SC.

//FORWARDED :: BY ORDER//

SECTION OFFICER